

NOTES:

1. Foundation stone shall be required when soil conditions are unsuitable.
2. An additional 1 inch depth of bedding material will be required for each additional 2 feet of trench depth in excess of 16 feet up to a maximum of 12 inches.
3. See specifications 31.23 17 section 3.12 bedding requirements as bedding depth relates to pipe material.
4. See [Detail C01.01](#) where trench rock is encountered for required clearances. Increase depth at bottom relates to bury. (Note 2 above)

SCALE: NTS

SCALE: NTS

NOTES:

1. The full length of the service trench shall be compacted in 6" layers with mechanical tamp.
2. Solvent cement for pvc pipe and fittings to be ASTM D-2564.
3. PVC eye, bend, lateral, & clean-out assembly must be bedded in #57 stone. Bedding and handling of service pipe must comply with Class B bedding (See bedding detail for gravity mains).
4. All fittings to be the same size as the existing eye.

SCALE: NTS

SCALE: NTS

SCALE: NTS

SCALE: NTS

SCALE: NTS

SCALE: NTS