

**ADDENDUM NO. 1
SCO ID# 19-20184-01A
NC DOT –Century Center
Contract Standards Office Upgrades
May 9, 2022**

To all bidding Contractors:

The following items supersede the bid documents dated April 12, 2022, and shall become a part of those bid documents with full force and effect, as though set forth therein. Bidders shall acknowledge receipt of this Addendum No.1 on the Form of Proposal.

Item 1: Specifications

Reference specification section 024119 – Selective Demolition, Section 1.7 Field Conditions; E Hazardous Materials: Remove entire text associated with E. Hazardous materials. There are no hazardous materials that the owner is aware of in this facility.

Item 2: Drawings

In reference to the metal stud partitions and the aluminum framed storefront vestibule. Metal stud partitions walls are to extend 4” above the lay-in ceiling. Aluminum storefront walls should be constructed to have bracing capabilities above the lay-in ceiling similar to the metal stud partition framing. The aluminum framed entrance can be fabricated with a 4’ – 6” head member that can extend above ceiling to allow bracing.

Item 3: Bid Opening date and time:

Bids will be received until 2:00 pm on Tuesday May 17, 2022 in Century Center Building B - **Riverwood Conference Room** at 1020 Birch Ridge Dr. Raleigh N.C. This is same location that the Pre-Bid meeting was held.

End of Addendum No. 1